Certificate No EUFI29-20003014-C/EN Issued July 10. 2020 Updated August 25, 2020 1 (7)

PRODUCT CERTIFICATE

Vilpe Oy

manufactures

wall outlet terminal devices IO 125 and IO 160

IO 125 ja IO 160 are intended to be used as wall outlet and inlet terminal devices of a residential ventilation. The wall outlet terminals comply with the requirements of the certification criteria *SERT R074: Requirements of wall outlet terminal devices for exhaust air and inlet terminal devices for outdoor air of a residential ventilation (Appendix 3).* Summary of the characteristics of the wall outlet terminal device IO 160, when outlet nozzle is damped with add-on is presented below. Summary of the wall outlet terminal device IO 160 without outlet nozzle damped with add-on and device IO 125 is presented in Appendix 1. Technical specification of the devices is presented in Appendix 2.

Property	Result	
Leakage	Meets the requirement.	
Aerodynamic performance (pressure /	The measured values correspond to the values declared by the	
air flow)	manufacturer.	
Acoustic performance	Lwa < 25 dB(A) to the external surrounding at nominal air flow.	
	Meets the requirements. The measured values correspond to the	
	values declared by the manufacturer. Meets the requirements.	
Air velocity of the exhaust air in outlet	5 m/s at nominal air flow 30 dm ³ /s (outlet nozzle damped with	
nozzle	add-on).	
Air velocity of the outdoor air in inlet	1.3 m/s at nominal air flow. Meets the requirement.	
grille of combination devices		
Throw pattern of exhaust air jet	Throw length 6.0 m (0.5 m/s) at nominal air flow. The measured	
	values correspond to the values declared by the manufacturer.	
Rainwater rejection efficiency of exhaust	Exhaust air: 98.7 % at nominal air flow (class B). Outdoor air:	
air outlet, and outdoor air inlet of	100 % at nominal air flow (class A). The removal of water from	
combination devices.	device has been implemented reliably. Meets the requirements.	
Amount of exhaust air in outdoor air flow	0 % at nominal air flow. Meets the requirement.	
of combination devices.		
Operation at low outdoor air	Operation tested at -20 °C outdoor temperature. Meets the	
temperatures	requirement	
Installation and maintenance guidelines,	Meets the requirements presented in Appendix 3.	
user manual		

This certificate is valid until July 9, 2022 on condition that the product is not essentially changed and the manufacturer and Eurofins Expert Services Oy have a valid contract on quality control. To check the validity of this certificate, www.sertifikaattihaku.fi. Other conditions are listed on the page 2 of the certificate

Espoo August 25, 2020

Tiina Ala-Outinen	Mikko Saari
Manager, certification and inspection	Asessor

This document has been signed electronically



Certificate No EUFI29-20003014-C/EN Issued June 10, 2020 Updated August 25, 2020 Valid until June 9, 2022 2 (7)

PRODUCT CERTIFICATE

Conditions of the validity of the certificate:

Where reference is made in this certificate to any regulations, publications, standards or other documents, it shall be construed as a reference to such publication in the form of which it is in force at the date of this certificate.

The manufacturer is responsible for the quality and continuous quality control of the product. In granting this certificate, Eurofins Expert Services Oy does not accept responsibility to any person or body for any loss or damage incurred in respect of personal injury arising as direct or indirect result of the use of this product.

The use of the name of Eurofins Expert Services Oy or the name Eurofins in any other form in advertising or distribution in part of this certificate is only permissible with written authorisation from Eurofins Expert Services Oy.

This certificate is the English version of the original EUFI29-20003014-C Finnish certificate. In case of dispute the Finnish original of the certificate is valid.



Certificate No EUFI29-20003014-C/EN Issued June 10, 2020 Updated August 25, 2020 Valid until June 9, 2022 3 (7) Appendix 1

PRODUCT CERTIFICATE

Summary of the characteristics of the wall outlet terminal device Vilpe IO 125, when outlet nozzle is damped with add-on.

Property	Result	
Leakage	Meets the requirement.	
Aerodynamic performance (pressure / air flow)	The measured values correspond to the values declared by the manufacturer.	
Acoustic performance	LwA < 25 dB(A) to the external surrounding at nominal air flow. The measured values correspond to the values declared by the manufacturer. Meets the requirements.	
Air velocity of the exhaust air in outlet nozzle	5 m/s at nominal air flow 18 dm ³ /s (outlet nozzle damped with add-on).	
Air velocity of the outdoor air in inlet grille of combination devices	0.80 m/s at nominal air flow. Meets the requirement.	
Throw pattern of exhaust air jet	Throw length 2.8 m (0,5 m/s) at nominal air flow. The measured values correspond to the values declared by the manufacturer.	
Rainwater rejection efficiency of exhaust air outlet, and outdoor air inlet of combination devices.	Exhaust air: 100 % at nominal air flow (class A). Outdoor air: 100 % at nominal air flow (class A). The removal of water from device has been implemented reliably. Meets the requirements.	
Amount of exhaust air in outdoor air flow of combination devices.	0 % at nominal air flow. Meets the requirement.	
Operation at low outdoor air temperatures	Operation tested at -20 °C outdoor temperature. Meets the requirement	
Installation and maintenance guidelines, user manual	Meets the requirements presented in Appendix 3.	

Certificate No EUFI29-20003014-C/EN Issued June 10, 2020 Updated August 25, 2020 Valid until June 9, 2022 4 (7) Appendix 1

PRODUCT CERTIFICATE

Summary of the characteristics of the wall outlet terminal device Vilpe IO 125 without outlet nozzle damped with add-on.

Property	Result	
Leakage	Meets the requirement.	
Aerodynamic performance (pressure / air flow)	The measured values correspond to the values declared by the manufacturer.	
Acoustic performance	LwA < 25 dB(A) to the external surrounding at nominal air flow. The measured values correspond to the values declared by the manufacturer. Meets the requirements.	
Air velocity of the exhaust air in outlet nozzle	5 m/s at nominal air flow 27 dm ³ /s (with outlet nozzle damped with add-on).	
Air velocity of the outdoor air in inlet grille of combination devices	1.2 m/s at nominal air flow. Meets the requirement.	
Throw pattern of exhaust air jet	Throw length 5.1 m (0,5 m/s) at nominal air flow. The measured values correspond to the values declared by the manufacturer.	
Rainwater rejection efficiency of exhaust air outlet, and outdoor air inlet of combination devices.	Exhaust air: 97.7 % at nominal air flow (class B). Outdoor air: 100 % at nominal air flow (class A). The removal of water from device has been implemented reliably. Meets the requirements.	
Amount of exhaust air in outdoor air flow of combination devices.	0 % at nominal air flow. Meets the requirement.	
Operation at low outdoor air temperatures	Operation tested at -20 °C outdoor temperature. Meets the requirement	
Installation and maintenance guidelines, user manual	Meets the requirements presented in Appendix 3.	

Certificate No EUFI29-20003014-C/EN Issued June 10, 2020 Updated August 25, 2020 Valid until June 9, 2022 5 (7) Appendix 1

PRODUCT CERTIFICATE

Summary of the characteristics of the wall outlet terminal device Vilpe IO 160 without outlet nozzle damped with add-on.

Property	Result	
Leakage	Meets the requirement.	
Aerodynamic performance (pressure / air flow)	The measured values correspond to the values declared by the manufacturer.	
Acoustic performance	L _{WA} < 25 dB(A) to the external surrounding at nominal air flow. The measured values correspond to the values declared by the manufacturer. Meets the requirements.	
Air velocity of the exhaust air in outlet nozzle	5 m/s at nominal air flow 44 dm³/s (with outlet nozzle damped with add-on).	
Air velocity of the outdoor air in inlet grille of combination devices	1.9 m/s at nominal air flow. Meets the requirement.	
Throw pattern of exhaust air jet	Throw length 6.7 m (0,5 m/s) at nominal air flow. The measured values correspond to the values declared by the manufacturer.	
Rainwater rejection efficiency of exhaust air outlet, and outdoor air inlet of combination devices.	Exhaust air: 96.4 % at nominal air flow (class B). Outdoor air: 100 % at nominal air flow (class A). The removal of water from device has been implemented reliably. Meets the requirements.	
Amount of exhaust air in outdoor air flow of combination devices.	0 % at nominal air flow. Meets the requirement.	
Operation at low outdoor air temperatures	Operation tested at -20 °C outdoor temperature. Meets the requirement	
Installation and maintenance guidelines, user manual	Meets the requirements presented in Appendix 3.	

Certificate No EUFI29-20003014-C/EN Issued June 10, 2020 Updated August 25, 2020 Valid until June 9, 2022 6 (7)

Appendix 2

PRODUCT CERTIFICATE

Product information of wall outlet terminal devices for exhaust air and inlet terminal devices for outdoor air of a residential ventilation.

Models: Vilpe IO 125 ja Vilpe IO 160

Manufacturer and representative of the devices: Vilpe Oy, Kauppatie 9, FI-65610 Mustasaari,

Finland. Tel: +358 20 123 3233, www.vilpe.com, myynti@vilpe.com

Outer dimensions: IO 125 ja IO 160: 427 mm (width), 238 mm (height) ja 201 mm (depth)

Weight: IO 125 0.96 kg, IO 160 1.0 kg Main manufacturing material: Polypropylene

Air duct connections: IO 125: duct diameter 125 mm, IO 160: duct diameter 160 mm Control of air flows: With low air flows the air velocity of the exhaust air in outlet nozzle may be increased by damped the outlet nozzle with add-on. Air velocity of the IO 125 exhaust air in outlet nozzle is 5 m/s at the air flow 27 dm³/s (without outlet nozzle damped) and the air flow 18 dm³/s (outlet nozzle damped with add-on). Air velocity of the IO 160 exhaust air in outlet nozzle is 5 m/s at the air flow 44 dm³/s (without outlet nozzle damped) and the air flow 30 dm³/s (outlet nozzle damped with add-on).



Certificate No EUFI29-20003014-C/EN Issued June 10, 2020 Updated August 25, 2020 Valid until June 9, 2022 7 (7)

Appendix 3

PRODUCT CERTIFICATE

Requirements of the certification criteria SERT R074: Requirements of wall outlet terminal devices for exhaust air and inlet terminal devices for outdoor air of a residential ventilation.

Property	Determination method	Requirement
Leakage	EN 1751	≤ 0.2 dm³/s at a test pressure of 250 Pa. 1)
Aerodynamic performance (pressure / air flow)	EN 12238	The measured values correspond to the values declared by the manufacturer. ²⁾
Acoustic performance	ISO 3741, ISO 5135	$L_{WA} \le 45$ dB(A) to the external surrounding at nominal air flow. The measured values correspond to the values declared by the manufacturer.
Air velocity of the exhaust air in outlet nozzle	q _v / A _{free area, minimum}	≥ 5 m/s at nominal air flow
Air velocity of the outdoor air in inlet grille of combination devices	q _v / A _{free area}	≤ 2.0 m/s at nominal air flow
Throw pattern of exhaust air jet	EN 12238	The measured throw patterns (velocity 0.5 m/s) correspond to the values declared by the manufacturer.
Rainwater rejection efficiency of exhaust air outlet, and outdoor air inlet of combination devices.	Tests with at least three air flows, EN 13030	≥ 80 % at applicable velocities. The removal of water from device has been implemented reliably.
Amount of exhaust air in outdoor air flow of combination devices.	Tracer gas method EN 13141-8, CFD-simulation, if necessary	≤ 0.6 % at nominal air flow, isothermal occasion without wind
Operation at low outdoor air temperatures	Performance test in laboratory applying EN 13141-8 3)	Operation tested and confirmed at -20 °C outdoor temperature. ³⁾
Installation and maintenance guidelines, user manual	Inspection and assessment 4)	Meets the requirements presented below 4)

Requirements:

- 1) Leakage: Leakage air flow rate at most 0.2 dm³/s at a test pressure of 250 Pa. Decree of the Ministry of the Environment on the type approval of the ventilation terminal devices. 2008.
- 2) Aerodynamic performance: Suitable air flow range and nominal air flow are declared by manufacturer. Air velocity of the exhaust air in outlet nozzle is calculated according to the free area of the nozzle If the free area is altered in the jet direction, minimum area is used.
- 3) Operation at low outdoor air temperatures (-20 °C, at least 6 hours): The freeze prevention and removal of condensated water from exhaust air has been implemented reliably. Frosting and freezing shall not affect negatively to the ventilation system or cause other hazards to the building or their users. During the test with exhaust air velocity 5 m/s the pressure drop shall increase at most 50 Pa or in actual operation, the air flow decreases at most 20 %. Temperature of exhaust air is 0 °C and relative humidity 70 95 %. Temperature of exhaust air is +5 °C in icicle test. Ice shall not accumulate in the device in such a way that it can cause danger if dropped (the mass of falling ice does not exceed 100 g).
- 4) Installation instructions: The junction between the device and the outer wall must be made in such a way that airtightness, watertightness and cold bridging are taken into account. Maintenance: Serviceability, cleanability and the functionality of any protective nets and air filters are assessed for pressure drop, possible blockage and bypass.